


SVA







CONTROL AND VISUALIZATION OF VOLTAGE AND FREQUENCY IN AC SINGLE PHASE LINES




Function	Voltage relay for single phase lines in AC. Powered by its own supply voltage, it makes the control of the voltage, the frequency and the DC voltage component on the line.		
Operating mode	Configurable by the user. Each one of the available relays it is assigned with its own operating mode for one or more magnitudes, reacting by the first one which is produced.		
Voltage control	· Operating margin: $\pm 18\%$ of the nominal voltage. · Operativity by maximum and/or minimum voltage. At each case, adjustment for detection and/or for release. · Reading value RMS		
Frequency control	· Adjustable from 43..70 Hz. · Operativity by maximum and/or minimum frequency. At each case, adjustment for detection and/or for release. · If the frequency changes in such a value that the relay loose the required precision for a normal operating mode, it switches to the alarm mode (See page 3 for detailed information).		
DC component control	· Adjustable from 0..3 VCC. · Operativity by maximum DC component. Adjustment for detection and/or for release.		
Timing	· Associable to the detection and/or to the release of whichever relay. · Adjustable from 0,01s..999,9h · Repeating precision ± 30 ppm		
Repeating precision	Up to 48 VCA: 0,01 V From 125 VCA: 0,1 V		
Voltage precision	Taken over the read value: A 50 HZ: 0,7 % · A 60 Hz: 0,8%		
Frequency precision	Taken over the read value: 0,3%		
Display of the reading value	The value of the read magnitudes is displayed by means of the following status screen: · VOLTAGE: Voltage in the line (VAC) · FREQUENCY: Frequency in the line (Hz) · DC COMPONENT: Component of the DC voltage in the line (VDC)		
Output relay	From 1..3 independent relays, SPST NO. By default, we supply three relays.		
Output 4-20 mA	It is assigned to whichever of the measured magnitudes (voltage, frequency, DC component) to be transmitted through a 4-20 mA current loop, being able to coexist with the relays. Precision: 1% additional to the read value. This kind of output is optional.		
PC communication	It is possible to establish different types of communication with a computer (see also last page): - By telephonic connector that incorporates standard device and CPBZ programming interface. - By a RS232 connection (optional). - By a RS2485 connection and SBAZ converter (optional).		
Operating margins according to the range (VCA)	-18%	Nominal	+18%
	19,68	24	28,32
	39,36	48	56,64
	90,20	110..125	147,50
	180,40	220..240	283,20
	311,60	380..415	489,70
	360,80	440	519,20



Communication (According options)

Standard Code 0	RS232 Code 3	RS485 Code 8	4-20 mA Code 4
			

Constructive and environmental data	Voltage phase-neutral	300 V
	Overtoltage category	III
	Shock voltage	4 kV
	Pollution degree	2 (EN61010)
	Protection	IP 20
	Approx. weight	280 g
	Store temperature	-30..+80°C
	Operating temperature	-20..+50°C
	Humidity	< 95% HR
	Housing	Cyclcoly - Light grey
	Leds window	Lexan - Transparent
	Buttons, connector, clamp	Technyl - Dark blue
	Connector's terminals	Brass
Screws torque	0,8 Nm	
Designed and manufactured under EEC normative. Directives referred: Electromagnetic compatibility: EMC 2004/108/EEC. Low voltage: LVD 2006/95/EEC. Hazardous substances: 2011/65/EEC Plastics: UL 91 V0		



SVA

Technical drawing of the SVA (Speaker Voice Amplifier) showing front and side views with dimensions:

- Front View:** A rectangular unit with a width of 52.5 and a height of 91.5. It features a top section with seven circular indicators (six on the left, one on the right) and a bottom section with five circular indicators. A small horizontal slot is located in the lower-middle section.
- Side View:** Shows the profile of the unit with a top width of 66 and a base width of 45. The total height is 81. The top surface is slightly curved.


GENERAL CHARACTERISTICS OF THE DIGITAL CONTROL RELAYS

User's manual	For a wide knowledge of the options offered by the digital control relays, the own User's Manual for each model must be read. Although an issue is given with every purchased device, a copy can be downloaded in our web site (www.disibeint.com).
How to programm	The digital control relays can be indistinctly programmed either with the buttons placed in the front of the housing or with a personal computer. Please refer at the end of this page to learn more about the PC programming alternative.
Types of screens	Status: They show the actual values of the magnitudes controlled by the relay. User: Where the user can write a customized text to help to the relay identification. Options: For accessing to the menus for the options selection. Informatives for values: They show the information of the different set parameters. Change of value: For modifying the values of the different values. Screens menus: Group of screens related under the same concept and that can contain whichever type of the screens previously described.
Interactive menus	For an ease programming, into the menus only the options that can be set are the ones visible. The rest of the options are not visible. This feature is interactive, ie., it is produced automatically according whether other functions are activated or not.
Changing values	The screens for changing the values contain the margins between such value can be adjusted. These margins can depend of other options and this is because different margins could be displayed according to other previous relations.
User's programmes	Provided by factory two programs with options and pre-configured settings for quick start-up team. In most cases, these parameters should be tweaked to suit the characteristics of each installation. The user can create your own program and store it on your computer.
Display lighting	The display remains backlit while it is accessed to the different screens. If any button is not pressed for longer than 30 seconds, the light turns off. In order to turn the light on, it is enough to press any button only once.
Value added	<ul style="list-style-type: none"> - Four languages available in each relay - Graphic bar for the intuitive visualization of the displayed value - Historical control of the maximum values obtained by the relay - Screen's refresh selectable between 1 and 8 times per second - Possibility of locking the keyboard to avoid any undesired modification - Complementary timing functions


SPECIFIC CHARACTERISTICS FOR THE MODEL SVH

Alarm by frequency deviation	<p>This option affects to those relays with any voltage parameter activated. By default, this option is activated. Inhibits the activation of the relay in the state of alarm when the frequency is deviated in $\pm 0,4$ Hz during the detection process, and of $\pm 0,3$ Hz during the release process.</p> <p>For this kind of deviation in the frequency, the operating precision is reduced. More the frequency in the net is deviated, worse precision when reading its voltage.</p> <p>If this option is deactivated, you must remember that the reading precision of the voltage parameters decrease when the frequency gets deviations from its nominal values (50 Hz / 60 Hz).</p> <p>You must consider this reduction of precision when setting the values for detection and/or release.</p>
------------------------------	--

PC COMMUNICATION

deCom	<ul style="list-style-type: none"> · Communication and programming software for the digital control relays. · It allows the interactivity between the different types of communication: through the CBPZ interface, RS232 or RS485. · It displays the complete data related to the relay, grouped by concepts and easing the intuitive programming. · It has control tools to do not exceed the operating margins of each model according to its range. · It is provided with templates to facilitate the programming of each model. · It allows to store the own settings. <p>Windows XP operative system (.NET Framework required).</p>	
-------	---	--

CURRENT LOOP 4-20 mA



ACCESSORIES

CBPZ



Interface for remote programming from a PC.
It allows the connection between whichever digital relay not provided with bus and a PC.
Not required for devices provided with bus RS232, RS485 or with 4-20mA output.


SBAZ





RS485 to RS232 signal converter for the remote programming or for the data capture and visualization from a PC.
It allows the connection of up to 31 digital control relays provided with RS485 communication bus, to get a unique codified RS232 output.

OUTPUTS COMMUNICATIONS
OUTPUTS COMMUNICATIONS FROM PC

STANDARD MODE

REMOTE PROGRAMMING
RS232 COMMUNICATION

* Connector RJ 12 (6 pins)
Seen from the cable entry




TxD — RxD 2
RxD — TxD 3
GND — GND 5





RS485 COMMUNICATION

* Connector RJ 10 (4 pins)
Seen from the cable entry



2 RxD — RxD 2
3 TxD — TxD 3
5 GND — GND 5



* Disibeint not supply cables or connectors.
You can find these products in stores specializing in computer equipment.

