

EQUIVALENCE OF REFERENCES
CNPR-D

The float switch for ATEX installations distributed for DISIBEINT ELECTRONIC SL with the reference

CNPR-D

has been referenced as

DF

to obtain the relevant certificates.

This is to confirm the veracity of the certificates attached to this document.



EC-Declaration of Conformity

We **MOLLET Füllstandtechnik GmbH**

Hans-Ulrich-Breymann-Str. 10
D-74706 Osterburken
Tel. +49 (0) 6291 64400 Fax +49 (0) 6291 9846

declare that the devices:

Rotary blade level indicator
Type **DF..A1B1...** and **DF..A2B1...**

to which this declaration relates is in accordance with the following standards or other normative documents:

Directive 94/9/EC (Directive ATEX)
Directive 89/336/EEC (Directive EMC)
Directive 73/23/EEC (Electrical equipment designed for use within certain voltage limits)
and

EN 50281-1-1:2000, EN 50014:1997+A1+A2
EN 1127-1:1997, EN 13463-1:2001, prEN 13463-5:2003,
EN 50281-1-2, CLC/TR 50404:2003
EN 55022, EN 55024, EN 61000-6-2
EN 1050, EN ISO 12100-1, EN ISO 12100-2,
EN 61010-1, EN 60204-1:1997

The Essential Health and Safety Requirements are assured by compliance with the directive and observance of the normative documents.

Production quality assurance:

**Qualitäts-
Management**

Regelmäßige freiwillige
Überwachung nach
DIN EN ISO 9001:2000



**Qualitäts-
Sicherungs-
System**

Anerkennung nach
Richtlinie 94/9/EG



The marking of the equipment includes the following:

for the electrical part:

CE **0032** **Ex** **II 1/2D T 80 °C IP 66** **-20 °C ≤ T_a ≤ +70 °C**
EC-type-examination Certificate Number **IBExU04ATEX1010X**

for the non-electrical part:

CE **0032** **Ex** **II 1D/2GD c IIB T X**
EC-type-examination Certificate Number **IBExU04ATEX1001X**

Osterburken, February 06, 2004



Wolfgang Hageleit