

CERTIFICATE OF THE COMPONENTS BELONGING TO INMB-Ex

The float switch for ATEX installations distributed for DISIBEINT ELECTRONIC SL with the reference

INMB-Ex

incorporates the component

.

LIMIT SWITCH SERIES PS

as main part of its manufacturing.

This is to confirtm the veracity of the certificates attached to this document.

EC-TYPE EXAMINATION CERTIFICATE [1] Equipment or Protective System intended for use [2] in potentially explosive atmospheres Directive 94/9/EC EC-Type Examination Certificate number: [3] CESI 01 ATEX 065 Limit switch series PS Equipment [4] COELBO STL Manufacourer. [5] Vis S. Margherita, 83 Brugheric (Milano) - Italy Address [6] This equipment or protective system and any acceptable variation thereto is specified in the schedule to this [7] certificate and the documents therein referred to. CESL notified body n. 0722 in accordance with Article 9 of the Council Directive 94/9/EC of 23 March 1994, certifies that this equipment or protective system has been found to comply with the Essential Health and Safety [8] Requirements relating to the design and construction of equipment and protective systems intended for use in potentially explosive atmospheres given in Annes II to the Directive. The examination and test results are recorded in confidential report p. EX-A1/026929. Compliance with the Essential Health and Safety Requirements has been assured by compliance with: [9] EN 50281-1-1: 1999 EN 50018: 2000 EN 50014: 1997 + A1_A2 [10] If the sign "X" is placed after the certificate number, it indicates that the equipment or protective system is subject to special conditions for safe use specified in the schedule to this certificate. This EC-TYPE EXAMINATION CERTIFICATE relates only to the design, examination and tests of the specified equipment or protective system in accordance to the Directive 94/9/EC. Further requirements of the Directive apply [11] to the manufacturing process and supply of this equipment or protective system. These are not covered by this certificate. The marking of the equipment or protective system shall include the following: [12] Ex) II 2 GD EEx d IIC T6 IP 65 T85 °C This certificate may only be reproduced in its entirety and without any change, schedule included. September 13, 2001 - translation issued on September 13, 2001 date Milauen CERT - A. Milancsi prepared CERT - M. Balaz verified ENMERTALE ITALIAND SHIDE REFINITED CERT - U. Colombo approved Business Unit Certificazione page 1/3

> CESI Contro Elettrotecnico Sperimentale Italiano Giacimo Motta Spa

Via R. Russatino 54 20134 Milano - Hala Telefono +38 922125.1 Fax +39 9221255440 Capitale sociale 8 550 000 Euro Interamente vorzeto Codice fiscale è numero Iscrizione CCIAA 00783580150 Registro Imprese di Milano Sezione Ordinaria N. R.E.A. 429222.

P.I. 1700783580150

CESI

Schedule

[14] EC-TYPE EXAMINATION CERTIFICATE B. CESI 01 ATEX 065

[15] Description of equipment

[13]

Limit switch series PS

Electrical characteristics

- Maximum rated voltage :	500 Vac.; 250 V d.c.
- Maximum rated current :	10 A
- Rated frequency :	50/60 Hz
- Degree of protection :	፲ ዮ 65

Temperature class - GAS

T6 for ambient temperature - 20 + + 40 °C - N. of operations / hour : no limits

65 °C for ambient temperature - 20 ÷ + 40 °C - N. of operations / 600

Maximum surface temperature T of the enclosure - DUST

TBS °C for ambient temperature - 20 + + 40 °C - N. of operations / hour : no limits

T65 °C for ambient temperature - 20 + + 40 °C - N. of operations / 600

The accessories used for the cable entry and for closing unused holes shall guarantee a degree of protection IP 65 and shall be certified according to the standards EN 50014, EN 50018 and EN 50281-1-1.

Warning label

None

This certificate may only be reproduced in its entirety and without any change, schedule included.

CESI

Schedule

[14] EC-TYPE EXAMINATION CERTIFICATE & CESI 01 ATEX 065

[16] Report n. EX-A1/026929

[13]

Individual tests

The manufacturer shall carry out the routine tests prescribed at clause 24 of the EN 50014 standard. The manufacturer is exempted from the routine overpressure test on the limit switches series PS since the apparatus has passed the type test performed with the static method at a pressure of 20 bar, equal to 4 times the reference pressure.

Descriptive documents (prot. EX-A1/026942)

- n. 5441/1 Rev. 1	dated	10.07.2001
- D. 5435/I Rev. 1	dated	26.04,2000
- 1. 5436/2 Rev. 2 (3 sheets)	dated	10.07.2001
- n. 5437	dated	23.02.1998
• n. 5190	dated	24.07.2001
- n. 5442/I Rev. 1	dated	10.07.2001
Safety instructions (4 shoets)	dated	06,07.2001
Dalicity monadula (4 proces)		

One copy of all documents is kept in CESI files.

- [17] Special conditions for safe use None.
- [18] Essential Health and Safety Requirements

Covered by standards.

This certificate may only be reproduced in its entirety and without any change, schedule included.